

Electric Department Monthly Report
August 2016

Trouble Calls:

- 8/01/16, 17 Waumbeck Road – outage due to tree breaking span of primary wire.
- 8/02/16, 142 College Road – outage due to wildlife.
- 8/02/16, 36 Center Street – bad transformer; failed and caused secondary to burn up.
- 8/07/16, 7 & 9 Estabrook – outage due to wildlife.
- 8/11/16, 9 Umbrella Point – dead birch tree resting on primary.
- 8/12/16, 573 GWH, 109E – logging truck ripped line from house (phone and cable).
- 8/13/16, 17 Osseo Drive – flickering lights; problem on customer’s side.
- 8/15/16, 77 Center St. – wire hanging down on right side of building (fire alarm cable).
- 8/18/16, 64 Cardinal Road – limb on primary.
- 8/19/16, Vicinity of 220 Beach Pond Road – motor vehicle accident.
- 8/21/16, 44 Corson Way – outage due to tree.
- 8/21/16, 734 Pleasant Valley Road, Brookfield – tree on primary.
- 8/22/16, 44 Corson Way – outage due to bad secondary wire.
- 8/24/16, 37 Knox Pasture Road – outage due to wildlife.
- 8/30/16, 54 Cotton Valley – outage due to wildlife.

- *Represents after-hour overtime callouts.*

Total Overtime (Man-hours) for Line Crew: 39.5 Hours

Electric Distribution Projects:

Work Orders Completed:

- 8/10/16, No. 4353, 7 River St., install tree guy and anchor.
- 8/11/16, No. 4362, 14 GWH, Tuftonboro – service upgrade from 100 Amp to 200 Amp overhead service.
- 8/12/16, No. 4342, 47 Penn Air Road – temporary service (200 Amp underground) for new garage construction.
- 8/23/16, No. 4365, 1 Oak Hill Road, Tuftonboro – replace pole and relocate meter to garage.
- 8/24/16, No. 4345, 35 Westwood Drive – install mid-span pole (low service).
- 8/24/16, No. 4336, 36 Mill St. - relocate service and add meter.
- 8/25/16, No. 4358, Grant road – System Improvement, replace pole and service.
- 8/29/16, No. 4335, 1139 Center St. – set permanent meter for new 200 Amp overhead service.
- 8/30/16, No. 4315, Nary Shores, Wolfeboro Common I – System Improvement.

General Service Orders Completed:

Forty-two (42) General Service Orders were completed including: dropping services for tree removals, disconnecting services for demolition, removing trees & branches from primary, repairing streetlights, pulling old poles, responding to voltage complaints, temporary services converted to permanent, covering services for siding/roofing and Line Design Tech appointments.

Miscellaneous Administrative Notes:

- Assisted with budget preparations and compiling back-up support data.
- Continue assisting with AMR project by preparing and uploading files to and from iPads to facilitate getting meter change-out data to the Billing Department.
- Updated department's Material Safety Data book and digital file.
- Updated transformer database and binder to include new transformers for Sewall Road project.
- Contacted Ossipee Mountain Electronics to schedule radio repairs for ME-3, ME-4 and ME-8.
- Prepared twelve NJUNS tickets notifying MetroCast and FairPoint of poles needing cable to be transferred.
- Prepared and submitted five Exchange of Notice Memos to FairPoint Communications.
- Sent three Right-of-Way Easements to Carroll County Registry for recording.
- Sent letters to four residents at 57 Mill St. notifying them of brief outage scheduled for August 24.

Electric Administration Projects:

- Work Orders # 4359-4367 staked and drafted by Bruce Gavarny.
- Met with Peter Cooke at the Pickering House to discuss options for power line relocation.
- Met with electrician Bill Keyes at 17 Osseo to review proposed service upgrade.
- Met with contractor John LaPolla on Fairway View Estates to discuss underground to new home.
- Attended TRC (Technical Review Committee) meeting.
- Met with customer at 13 Friar Tuck to resolve damaged service entrance cable issue.
- Met with electrician Tim Christian at 20 Pine Harbor to discuss service upgrade to condo.
- Responded to email questions from Keniston Island residents regarding pole line relocation.
- Drafted electric service deficiency letter templates for AMR project and mailed eight (8).
- Met with *Eversource* Meter Technician at the RIB site to change out the meter.
- Conversated with *FairPoint* electrician Mike Krenza regarding service upgrade at their building located on the corner of School and Glendon Street.
- Met with CJ Cincotta regarding service upgrade required at 14GWH, Tuftonboro.
- Checked on availability of power for property on Greenleaf Drive for potential new home.
- Met with ICMA 457 representative to discuss programs with new staff members.
- Met with representative from *Kerite Cable*, Ed Sleight to discuss submarine cable options to Islands.
- Located and marked underground cable at 324 Cotton Valley Road for Public Works project.
- Scheduled outage for completion of the Wolfeboro Commons I project.
- Met with contractor Randy Hoyt on Abenaukee Drive to discuss new electric service options.
- Conversated with potential property owner on Alpine Meadows regarding power line extension.
- Conversated with *TNT Electric* about cable replacement project for Wolfeboro Marketplace.
- Met with Suzanne Ryan of Stoneham Road regarding policies of utilities on Class VI roads.

Electric Administration Projects Continued:

- Met with electrician Bill Dixon to discuss service relocation at 30 Port Wedeln Road.
- Reviewed system improvement on Country Lane in Tuftonboro with Bruce Gavarny for work order draft.
- Met with contractor Gary Ciccarone on Blackberry lane to discuss proposed new underground service to new home.
- Checked on “Dig Safe” request for Public Works culvert replacement on Forest Road.
- Drafted letters to *MetroCast* and *FairPoint* detailing the Sewall Road pole replacements.
- Worked on 2017 Budget submittals.
- Located and marked underground utilities at #4 Shore Road.
- Met with contractor John LaPolla regarding work required at the Armory building.
- Met with Greg Dollarhide to discuss new electric service to garage on South Main Street.
- Met with electrician Jim Bean to discuss service upgrade at 308 South Main Street
- Continued installation of AMR meters throughout the month as time allowed.

Meter Division:

- Completed 119 work orders generated by the Billing Office, which included final reads, check reads and customer request disconnects.
- Meters stopped recording and replaced at 53 Shore Rd. Alton, 65 King Pine Rd., 261 Center St., 2 Birch Hill Estates, 8 Council Tree Ln., 50 North Main St., 428 GWH and 15 Tibbetts Rd.
- Disconnected and reconnected one customer for nonpayment.
- Installed AMR meters in East Alton (Route #12).
- Inspected an installed net meters in Photovoltaic services at 515 and 603 Stoneham Rd.
- Meters removed from temp service at 6 Hopewell Road and 108 Sewall Road.
- Meter installed in temporary service at 47 Penn Air Road.
- Delivered *Disconnect Notices* for the Billing Department (Nonpayment).
- Continued ongoing meter testing as required.
- The meter readers met monthly billing cycle for August.

Miscellaneous:

- Updated Demand Account spread sheet.
- Assisted Line Crew with broken pole accident on Beach Pond Rd.

Tree Trimming:

- *Urban Tree* continued work on Sewall Rd. W.O. #385
- *Top Notch* Crane Crew cut and removed large assigned trees on Sewall Road and GWH Tuftonboro.
- General Orders completed by *Urban Tree*:
 - #4353 River St.
 - #7067 Pleasant Valley Rd.
 - #7137 Clark Rd.
 - #7297 Whitten Neck Rd.
 - #6915 Osseo Dr.
 - #7132 Winterhaven Road
 - #7296 Pine Hill Rd.