Wolfeboro Fire-Rescue Department

One and Two Family Dwelling Certificate of Occupancy checklist

Fire Prevention Division 569-1400

Pass	Fail	N/A	
	-		> (new construction) At least one egress window from all sleeping and living areas (opens min. 20 inches wide, 24 inches high AND 5.7 square feet) or door
			directly to outside.
			 > (existing construction) At least one egress window from all sleeping and living areas (opens min. 20 inches wide, 24 inches high) or door directly to outside.
			 > (new construction and additions) Smoke detectorsinterconnected, hardwired, battery back up. One in each sleeping area, vicinity of each sleeping area, and at least one on every level including the basement (not required in attic/crawl space). Door directly from living/sleeping area to outside removes "vicinity" requirement. Also, carbon monoxide detectioninterconnected, hardwired, battery backup, at least one on every level including the basement. Combination smoke/CO detectors OK.
			> All deck/stair railings and/or guards installed where over 30 inches to surrounding grade. Guards min 36" high and must pass 4-inch sphere rule. Stairs shall have graspable rail.
			> Fireplace/woodstove chimneys must be lined. Minimum 16" hearth, hearth extends 8" to each side of opening. If firebox opening > 2x3 ft, 20" hearth. Chimney 2 feet higher than any obstructions within 10 feet, must be at least 3 feet higher than where it passes through roof. Interior chimney at least 2" clearance from
			combustibles; exterior at least 1"] > Street number posted and visible from street.
] > Modular homes onlycheck for State of NH modular sticker/approval number for each box
	Persor	n perfo	rming inspection Date

Notes: