

WOLFEBORO FIRE/RESCUE DEPARTMENT

569-1400 BUSINESS LINE

WOODSTOVE INSPECTION CHECKLIST

DATE	GROUP	OFFICER
ADDRESS		TYPE OCCUPANCY
OWNER	TENANT *	

* TENANT MUST HAVE WRITTEN PERMISSION FROM PROPERTY OWNER

	YES	NO
Is the stove free of cracks or broken parts?		
The stove has manufacturer's directions and is installed accordingly?		
The chimney is clean, and is equipped with a cleanout?		
Chimney is masonry with a liner, NO tin plates covering holes, and is in good condition? OR Chimney is factory built and is installed according to manufacturer's instructions?		
The chimney extends 3 feet above roof and 2 feet from all projections within 10 feet measured horizontally?		
There is only THIS wood appliance into flue?		
The stove pipe is fastened at each joint and firmly attached to stove and chimney?		
The stove pipe has a damper or one is built into the stove?		
The stove pipe is 18 inches from combustibles or is properly protected?		
The stove pipe does not pass through a wall without proper protection?		
The stove is 36 inches from combustibles or proper protection is provided?		
Floor protection is proper for legs that are _____ from the floor?		
Floor protection extends 12 inches sides or rear, 18 inches front?		
A 36-inch area from the stove is free of paper, firewood, or furniture?		
A metal container with a lid is provided for ashes, and the occupant told that ashes stay HOT up to five days?		
The house has at least one 2½ pound fire extinguisher?		
The residence has properly installed smoke alarms?		
Is the house number posted and readable?		

RECOMMENDATIONS